

October 15, 2003

AERO-STREAM  
KARL K. HOLT

PO BOX 700  
MERTON WI 53056

Re: Description: CHEMICAL OR PHYSICAL RESTORATION FOR POWTS  
Manufacturer: AERO-STREAM  
Product Name: AERO-STREAM  
Model Number(s): QT800 AND QT800HW  
Product File No: 20030383

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of October 2008.

This approval is contingent upon compliance with the following stipulation(s):

- This product must be utilized in accordance with the manufacturer's printed installation instructions and this product approval. If there is a conflict between the manufacturer's installation instructions and the product approval, the product approval requirements will take precedence.
- The elevation of the system's infiltrative surface must be above the estimated highest groundwater elevation or bedrock by the distance prescribed in column entitled "Fecal Coliform >10000 cfu/100 ml" in Table Comm 83.44-3, Wis. Adm. Code.
- When this product is installed in a septic tank, the outlet baffle of the septic tank must have installed an effluent filter, which is capable of filtering particles of 1/32 inch in size or larger.
- This product may have its sintered air stones installed in a distribution box, seepage pit, dose tank, or the most downstream septic tank.
- When this product has its sintered air stones installed in a septic tank, a properly licensed person must perform the installation.
- A state Sanitary Permit must be obtained when this product is installed in a septic tank that is required to have an effluent filter installed, which is capable of filtering particles of 1/32 inch in size or larger.
- A copy of this approval letter and the manufacturer's printed installation instructions must be supplied to the buyer of this product.

This approval supersedes the approval issued on INSERT DATE under product file number #20020396.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

AERO-STREAM  
Page 2  
October 15, 2003

Sincerely,

Michael J. Beckwith, CIPE  
Plumbing Product Reviewer  
phone: 608-266-6742  
fax: 608-267-9566  
e-mail: [mike.beckwith@wisconsin.gov](mailto:mike.beckwith@wisconsin.gov)